

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR  
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Electromechanical contactor for household and similar purposes

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.  
No. 7, Zhenxing Road, Xinguang Industrial Zone,  
Liushi, Yueqing, Zhejiang,  
CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: *When more than one factory, please report on page 2*

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)

**Aoelec**

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

AUC6-25/2, AUC6-25/4, AUC6-63/2, AUC6-63/4

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61095:2009

As shown in the Test Report Ref. No. which forms part of this Certificate

190602013SHA-001, 190602013SHA-002

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 28 October 2019

**intertek**

Signature:

  
Henrik Wikström

**Ratings and principal characteristics**

Model:	AUC6-25/2, AUC6-25/4			
Ratings:	Ue=230V(2P), 400V(4P) Ith=25A, Us=24/48/230Vac, Ir=Iq=3kA, Ui=500V, Uimp=4kV			
Category:	AC-7a			
Ue:	230V	400V	230V	400V
Ie:	20, 25A	20, 25A	9A	9A

Model:	AUC6-63/2, AUC6-63/4			
Ratings:	Ue=230V(2P), 400V(4P) Ith=63A, Us=24/48/230Vac, Ir=Iq=3kA, Ui=500V, Uimp=4kV			
Category:	AC-7a			
Ue:	230V	400V	230V	400V
Ie:	25, 40, 63A	25, 40, 63A	16, 32A	16, 32A

Date: 28 October 2019

Signature: