



Ref. Certif. No.

SE-113810

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.
No.7, Zhenxing Road, Xinguang Industrial Zone, Liushi, Yueqing, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Additional Information on page 2

Note: *When more than one factory, please report on page 2*

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)

Aoelec

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

AUR8-100

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-2-1:1990
IEC 61008-1:2010+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

2403B0132SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 22 April, 2024

intertek

Signature:


Anneli Averland Johansson



Ref. Certif. No.

SE-113810

Factories

1. Wenzhou Aoelec Electrical Co., Ltd.
No.7, Zhenxing Road, Xinguang Industrial Zone, Liushi, Yueqing, Zhejiang, China
2. Zhejiang Aoelec Electrical Co., Ltd.
Chiyan Village, Chuanliao Town, Qingtian County, Lishui City, Zhejiang Province, China

Ratings and principal characteristics

Un= 230/240V~ 2P(1P+N), 400/415V~ 4P(3P+N), 50/60Hz

Inc= IΔc= 10000A

Without time delay:

In= 16 (only for 2P), 25, 40, 63, 80, 100A

IΔn= 0,03, 0,1, 0,3A; Type -A & -AC

With time delay: Type S

In= 40, 63, 80, 100A

IΔn= 0,1, 0,3A; Type -A & -AC.

Additional information

The requirements for

EN 61008-1:2012+A1:2014+A2:2014+A11:2015+A12:2017 used in conjunction with

EN 61008-2-1:1994+A11:1998, BS EN 61008-1:2012+A12:2017 and

AS/NZS 61008.1:2015 have also been checked.

Date: 22 April, 2024

Signature: