

 **CERTIFICATE**
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2400397

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Type designation: AUR8-100

Certificate holder: Wenzhou Aoelec Electrical Co., Ltd.
No. 7 Zhenxing road, Xinguang Industrial Zone,
Liushi Yueqing, Zhejiang, China

**The product complies with
the standard(s):** EN 61008-1:2012+A1+A2+A11+A12
EN 61008-2-1:1994 and A11

Date of expiry: 22 April, 2029

EU Directive information: The product listed has been evaluated by a Third-Party Body and deemed to meet the listed harmonized standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:

Date: 22 April, 2024


Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

APPENDIX:

Reference No. SE-S-2400397

Technical Data:

Type designation	AUR8-100
Rated voltage (V)	230/240V~ 2P(1P+N), 400/415V~ 4P(3P+N)
Rated current (A)	Without time delay: 16(only for 2P), 25, 40, 63, 80, 100A With time delay (Type S): 40, 63, 80, 100A
Frequency (Hz)	50/60
IP-Class	20
Poles No.	1P+N, 3P+N
Trademark	Aoelec
Test Report	2403B0132SHA-001
Product information	Inc= $I\Delta c = 10000A$, Type -A & -AC Without time delay: $I\Delta n = 0,03, 0,1, 0,3A$ With time delay (Type S): $I\Delta n = 0,1, 0,3A$.

Manufacturing Sites:

Wenzhou Aoelec Electrical Co., Ltd.
No. 7 Zhenxing road, Xinguang Industrial Zone,
Liushi Yueqing, Zhejiang, China

Zhejiang Aoelec Electrical Co., Ltd
Chiyan Village, Chuanliao Town, Qingtian County, Lishui City,
Zhejiang Province, China

The instructions for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 22 April, 2024

Anneli Averland Johansson

Intertek

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.