



Ref. Certif. No.

**SE-108208M1**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Wenzhou Aoelec Electrical Co., Ltd.  
No.7, Zhenxing Road, Xinguang Industrial Zone, Liushi, Yueqing, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Additional Information on page 2

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See page 2

**Aoelec**

Trademark / Brand (if any)

-

Customer's Testing Facility (CTF) Stage used

KBF

Model / Type Ref.

Additional Information on page 2

Additional information (if necessary may also be reported on page 2)

IEC 60898-1:2015+A1

A sample of the product was tested and found to be in conformity with

2404B0707SHA-001

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Date: 28 May, 2024

**intertek**

Signature: Quan Li



Ref. Certif. No.

**SE-108208M1**

## Factories

1. Wenzhou Aoelec Electrical Co., Ltd.  
No.7, Zhenxing Road, Xinguang Industrial Zone,  
Liushi, Yueqing, Zhejiang, China

2. Zhejiang Aoelec Electrical Co., Ltd.  
Chiyan Village, Chuanliao Town, Qingtian County,  
Lishui City, Zhejiang Province, China  
Additional information

## Ratings and principal characteristics

Ue= 230/400 or 240/415V~(1P), 230 or 240V~(1P+N), 400 or 415V~(2P, 3P, 3P+N, 4P), 50/60Hz;  
In= 6, 10, 13, 16, 20, 25, 32, 40, 45, 50, 63A; B-, C- & D- type;  
Icn= Ics= 6000A, Energy limiting class 3 (only for B- & C- type);  
For 1P+N and 3P+N, N pole is the unprotected switched neutral pole.

## Additional information:

This certificate replaces CB certificate SE-108208, dated 01 June 2022. A new certificate has been issued on account of adding models of 1P+N and 3P+N, adding an alternative factory "Zhejiang Aoelec Electrical Co., Ltd.".

The requirements for EN 60898-1:2019, BS EN 60898-1:2019 and AS/NZS 60898.1:2004 have also been checked.

Date: 28 May, 2024

Signature: 