

Test Verification of Conformity

Verification Number: 2404B0707SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Wenzhou Aoolec Electrical Co., Ltd. No.7, Zhenxing Road, Xinguang Industrial Zone, Liushi, Yueqing, Zhejiang, China
Manufacturing site Name & Address:	1. Wenzhou Aoolec Electrical Co., Ltd. No.7, Zhenxing Road, Xinguang Industrial Zone, Liushi, Yueqing, Zhejiang, China 2. Zhejiang Aoolec Electrical Co., Ltd. Chiyan Village, Chuanliao Town, Qingtian County, Lishui City, Zhejiang Province, China
Product Description:	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Ratings & Principle Characteristics:	Ue= 230/400 or 240/415V~(1P), 230 or 240V~(1P+N), 400 or 415V~(2P, 3P, 3P+N, 4P), 50/60Hz; In= 6, 10, 13, 16, 20, 25, 32, 40, 45, 50, 63A; B-, C- & D- type; Icn= Ics= 6000A, Energy limiting class 3 (only for B- & C- type); For 1P+N and 3P+N, N pole is the unprotected switched neutral pole KBF
Models/Type References:	
Brand Name(s):	
Standard(s)/Directive(s):	EN 60898-1:2019 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2024-04-16 to 2024-05-21
Test Report Number(s):	2404B0707SHA-001



Signature

Name: Oliver Wei
Position: Manager
Date: 30 May 2024